

T A
Č R



Pilot operation of Vdip system Description

Operating period: 10/2020 – 12/2022

Author: David Topolanek

Contact: topolanek@vut.cz

Content

| | |
|----------------------------------------------------|---|
| Description of pilot operation..... | 3 |
| Pilot operation evaluation..... | 5 |
| Summary evaluation of pilot operation results..... | 5 |

Description of pilot operation

The pilot operation of the Vdip system was implemented in a compensated 22 kV network with a capacitive current of 83A (overhead lines with a minimum share of cables).

The MV network is supplied from the primary substation 110/22 kV, belonging to distribution network operator EG.D. One MV feeder (Kubova Hut') was allocated for the installation of the Vdip system.

The monitored feeder consists of 326 nodes, 233 line sections, 96 switching elements, 61 distribution transformer stations MV/LV from which 16 were equipped with distributed measurement unit (DMU) on LV side. The total length of monitored feeder including branches is 82 km.

The monitored feeder of the network is shown in Fig. 1 (green) together with the DMU disposition (blue circles). In the standard operation state, the feeder is operated radially, where the loops of MV lines are disconnected in the places marked with a brown arrow (disconnecter 820 and Bytovky). As part of the pilot operation, class A power quality meters with the possibility of signal analysis up to 9 kHz were used as DMUs. These DMUs record oscillograms of phase voltages when a fault occurred and on request transferred them to the Vdip system centre for data processing and evaluation. These DMUs represent negative sequence voltage monitors (NSVM), where a sampling frequency of 4 kHz was used for the fault recordings during the pilot project. In the primary substation, an RTU was installed on the monitored MV feeder, which substituted the function of the feeder protection, as it was not possible to directly download fault records from the feeder protection using the DSO infrastructure. For the purposes of the Vdip system, fault record of feeder protection is used as the negative sequence current monitor (NSCM).




Fig. 1: Topology of MV feeder selected for pilot operation of system Vdip

Pilot operation evaluation

In order to test the developed prototype of the Vdip system, a pilot operation was launched in the presented network on 10/2020 and extended until the end of 2022. During this pilot, a total of 9 permanent faults occurred, which could be localized a total of 23 times, as in most cases the fault was reenergized several times. The list of all detected faults together with performed localizations is summarized in Table 1. For illustration, a detailed analysis of the Vdip localization process is demonstrated using only a few selected faults No. 2, 5, 9 and 13 (Tab. 1), available on web page [1].

Tab.1: List of faults localized by the Vdip system and found by DSO during pilot test

| No. | Date | Fault Description | | Real Fault Location | DMU records | Segments | | Lokalizace | | Note |
|-----|-------------------------|-------------------|----------------------------|---------------------|-------------|----------|--------------------|-----------------|---------------------|----------------------------------|
| | | Type | Characteristic | | | No. | Seg. Error (km) | Loc. Error (km) | Fault Distance (km) | |
| 1 | 2020-10-27 22:28:21.387 | SC | EF in L2 to SC L1-L2 | Yes | 17 | 2 | 6; 6 | 6 | 26,5 | Successful localization |
| 2 | 2020-10-27 22:31:04.529 | SC | EF in L2 to SC L1-L2 | Yes | 17 | 2 | 0,07; 0,07 | 0,07 | 25,4 | Successful localization |
| 3 | 2021-02-04 3:53:46.359 | EF | EF arcing L1 | Yes | 17 | 1 | 0 | 0 | 23,5 | Successful localization |
| 4 | 2021-02-04 3:54:11.509 | EF | EF arcing L1 | Yes | 17 | 4 | 0,6; 1,6; 1,4; 1,7 | 0,6 | 23,5 | Successful localization |
| 5 | 2021-02-04 3:56:38.119 | EF | EF arcing L1 | Yes | 17 | 3 | 0,7; 0; 0,3 | 0,7 | 24,7 | Successful localization |
| 6 | 2021-03-13 15:26:05.262 | EF | EF arcing L3 (short therm) | 2021-07-08 | 17 | 1 | 1,1 | 1,1 | 16,8 | Supposed fault location |
| 7 | 2021-06-29 17:42:04.228 | SC | EF in L3 to SC L1-L2 | Yes | 17 | 2 | 0,7; 0,5 | 0,7 | 32,1 | Successful localization |
| 8 | 2021-06-29 17:43:56.448 | SC | SC L1-L2 | Yes | 17 | 2 | 0,7; 0,5 | 0,7 | 32,1 | Successful localization |
| 9 | 2021-06-29 17:45:36.818 | SC | SC L1-L2 | Yes | 17 | 2 | 0,7; >5 | 0,7 | 32,1 | Successful localization |
| 10 | 2021-07-08 15:48:14.571 | SC | Cross Country EF L3-L1 | Yes | 17 | 3 | | Incorrect | | Impossible cross EF localisation |
| 11 | 2021-07-08 15:50:16.171 | SC | Cross Country EF L3-L1 | Yes | 17 | 2 | | Incorrect | | Impossible cross EF localisation |
| 12 | 2021-07-08 15:52:55.141 | SC | Cross Country EF L3-L1 | Yes | 17 | 2 | | Incorrect | | Cross Country Fault |
| 13 | 2021-07-08 15:54:18.271 | EF | EF in L3 | Yes | 16 | 2 | 0,1; 0,1 | 0,1 | 18,1 | Successful localization |
| 14 | 2021-07-08 15:54:20.181 | EF | EF L3 + auxiliary resistor | Yes | 16 | 2 | 0,1; 0,1 | 0,1 | 18,1 | Successful localization |
| 15 | 2021-11-30 09:20:17.155 | SC | L2-L3 + auto reclosing | Yes | 5 | 4 | 1,4; 1,4; 1,4; 1,4 | 1,4 | 24,2 | Limited DMUs |
| 16 | 2021-11-30 09:20:18.855 | SC | L2-L3 + auto reclosing | Yes | 5 | 4 | 1,4; 1,4; 1,4; 1,4 | 1,4 | 24,2 | Limited DMUs |
| 17 | 2021-11-30 09:21:34.895 | SC | L2-L3 | Yes | 4 | 2 | 1,4; 1,4 | 1,4 | 24,2 | Limited DMUs |
| 18 | 2021-11-30 09:24:11.545 | SC | L2-L3 | Yes | 4 | 2 | 1,4; 1,4 | 1,4 | 24,2 | Limited DMUs |
| 19 | 2021-11-30 09:59:51.208 | SC | SC L2-L3 | Yes | 2 | 2 | 1,4; 1,4 | 1,4 | 24,2 | Insufficien No. of changes |
| 20 | 2022-01-19 12:26:26.473 | EF | EF L1 | Yes | 7 | 0 | x | x | x | No segment, disturbance/nois |
| 21 | 2022-01-19 12:28:18.713 | EF | EF L1 | Yes | 6 | 0 | x | x | x | No segment |
| 22 | 2022-02-16 09:29:58.589 | SC | EF L1 to SC L1-L2 | Yes | 3 | 4 | >5; >5; >5; >5 | >5 | 24,2 | Insufficien No. of changes |
| 23 | 2022-12-06 05:48:50.838 | EF | Arcing EF in L3 | Probable | 5 | 2 | >5; >5 | >5 | 16,8 | Two different EF in 3 hours |

Summary evaluation of pilot operation results

Table 1 summarises the results of the localization based on fault records of all the discovered faults. The "Type" column describes the type of fault – short-circuit (SC) or earth fault (EF) – and is complemented by a brief description of the fault specifics. In Table 1, only faults found by the DSO are listed, with the exception of fault No. 6, which was not discovered, but the fault location estimated by the Vdip matches a fault which occurred 4 months later. The "DMU records" column defines the number of fault records received from the DMUs (NSVMs). The table shows that from fault No. 15 onwards, there was a significant drop in amount of received records having a major impact on the ability of the Vdip system to correctly locate the fault.

The "Segments" column shows the number of synchronization segments detected and relevant localization error (the electrical distance between the real location and the location estimated by Vdip system). The first value of Seg. Error corresponds to the segment that was selected as the result of the fault localization by the Vdip system. The "Localization" column then indicates the electrical distance

of the real fault location from the location determined by the Vdip and the distance of the fault from the substation.

Based on the results of fault localization by the Vdip system, it can be stated that for most of the records it was possible to locate the fault with an error of up to 1.5 km. In the case of faults 15 to 23, it is necessary to take into account the effect of a rather large and long-lasting failure of communication between the central unit and the DMUs, which significantly reduced the Vdip localization performance (due to the lower availability of DMU location, the restoration of communication capability was postponed until 2023, when the HW upgrade will take place).

In the case of faults 10 to 12, the Vdip system was unable to successfully locate the fault as it was a cross country (double) earth fault. This type of fault cannot be localized by the Vdip algorithm at this time (for this reason faults 10 to 12 were not evaluated). Localization of this type of fault is only possible after disconnection of one single earth fault, as can be seen in faults 13 and 14, which could be further successfully localized.

References

[1] *Solutions for energetics | ELVAC a.s.* [online]. Available on: <https://www.rtu.cz/microsite/vdip>